

**SCS Global Services** does hereby certify that an independent assessment has been conducted on behalf of:

# MetroFlor Corporation

15 Oakwood Avenue, Norwalk, CT, United States

For the following product(s):

**Flooring Adhesives:**  
Prevail 3500, Prevail 4000

The product(s) meets all of the necessary qualifications to be certified for the following claim:

## **FloorScore®**

Indoor Air Quality Certified to SCS-EC10.3-2014 v3.0

Conforms to the CDPH/EHLB Standard Method v1.1-2010 (effective January 1, 2012) for the school classroom, private office, and single-family residence parameters when modeled as Flooring. Also, conforms to the SCAQMD Rule 1168 - Adhesive and Sealants (January 2005); Hong Kong Air Pollution Control (VOC) Regulation.

Highest Specified Product Application Amount: 4200 g/m<sup>2</sup>

Measured Concentration of Total Volatile Organic Compounds (TVOC): Between 0.5 – 5.0 mg/m<sup>3</sup> (in compliance with CDPH/EHLB Standard Method v1.1-2010)

Methylene Chloride and Perchloroethylene are not intentionally added to certified products.

Registration # SCS-FS-03549

Valid from: March 1, 2017 to February 28, 2018

SCS Global Services is currently the only certification body approved by the Resilient Floor Covering Institute (RFCI) to provide FloorScore® product certification; certified products are only listed on the SCS Green Products Guide, <http://www.scsglobalservices.com/certified-green-products-guide>.



ANSI ACCREDITED PROGRAM  
PRODUCT CERTIFICATION  
#0821



A handwritten signature in black ink that reads "Stanley Mathuram".

Stanley Mathuram, PE, Vice President  
SCS Global Services  
2000 Powell Street, Ste. 600, Emeryville, CA 94608 USA